

## CORRIGENDUM

TENDER REF: IFB: GAPL/TENDER/CAP/005/2018-2019/ DATE: 23/11/2018  
TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF DOUBLE  
SKIN AIR HANDLING UNIT

### AMENDMENT

REF. NO.	SPECIFICATION AS PER TENDER	TO BE READ AS BELOW:
CHAPTER 2.4 SR.NO.2.4.4 CHAPTER - 3 ANNEXURE – I SR.NO.1	PRE-FILTERS (G4), MICROVEE FILTERS (F6) AND SUPER FINE FILTERS (F9) ARE LOCATED IN AHU.	PRE-FILTERS (G4), MICROVEE FILTERS (F6), SUPER FINE FILTERS (F9) & HEPA FILTERS (H- 14) ARE LOCATED IN AHU.
CHAPTER 3 ANNEXURE- I SR.NO.1.1	AHU- 2 COOLING LOAD TR 22	COOLING LOAD TR 25.5
SR.NO.1.3	AHU- 5 COOLING LOAD TR 11	COOLING LOAD TR 12.75
<b>SR.NO.2.</b>	<b>AHU DX CONDENSING UNIT</b>	
SR.NO.2.2	8.5TR – 1NO	8.5TR – 4NOS
SR.NO.2.3	11 TR – 3NOS	11 TR – 1 NO
SR.NO.2.5	NIL	4.25 TR – 1 NO
CHAPTER NO.4 SR.NO.13.2.D	THE BIDDER PARTICIPATED IN THE TENDER REF.NO. GAPL/TENDER/CAP/006/2017-2018 DATED 14.02.2018 AND TECHNICALLY QUALIFIED NEED NOT SUBMIT THE TECHNICAL BID AGAIN.	<b>ALL VENDORS SHOULD SUBMIT BOTH TECHNICAL AND PRICE BID.</b>
		CONSIDERING THE AHU ROOM DIMENSION OF 5MTRS X 5.25 MTRS AND HEIGHT 2.8 MTRS, DESIGN WITH DOUBLE DECKER SYSTEM MAY BE ACCEPTED.